

From: webmaster@cpuc.ca.gov

Sent: Monday, October 26, 2020 10:39:12 AM (UTC-08:00) Pacific Time (US & Canada)

To: USRB

Cc: paul.pimentel@sce.com

Subject: Electric Safety Incident Reported- Southern California Edison Company Incident No: 201026-13677

The Following information regarding this incident has been reported:

Reporting Date: 10/26/2020 10:32:55 AM

Incident Date: 10/26/2020 @ 6:45 a.m.

Reported By: Paul C. Pimentel, Senior Manager

Utility Name: Southern California Edison Company

Phone Number: (626)695-4705

Email Address: paul.pimentel@sce.com

Incident Location: Santiago Canyon Road Santiago Canyon, Orange County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Taiwan
- Voltage (KV): 12 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report as it may involve an event that meets the subject of significant public attention or media coverage reporting requirement. Preliminary information reflects SCE overhead electrical facilities are located in the origin area of the Silverado Fire. We have no indication of any circuit activity prior to the report time of the fire, nor downed overhead primary conductors in the origin area. However, it appears that a lashing wire that was attached to an underbuilt telecommunication line may have contact SCE's overhead primary conductor which may have resulted in the ignition of the fire. The investigation is ongoing.